



Lessons Learned in Wind Integration

Dan Woodfin
Director, System Operations


NECPUC Symposium

May 21, 2012

The ERCOT Region

The interconnected electrical system serving most of Texas, with limited external connections

- 75% of Texas land; 85% of Texas load
- 68,294 MW peak demand (set August 3, 2011)
- More than 40,000 miles of transmission lines
- 2 DC ties with SPP; 3 DC ties with Mexico; 1106 MW total
- 550+ generation units




Markets

- Fully unbundled Wholesale market
 - ERCOT operates a single Control Area with ancillary services markets
 - Generators are paid Locational Marginal Prices (LMPs) at their node
 - Load-serving entities pay averaged load-zone prices
- Full Retail competition except in municipal & co-op utility areas

Transmission Service

- All transmission costs are rolled-in to single postage-stamp rate paid by load
- All generators have, essentially, “network service”



ERCOT Inc.:


A non-profit corporation designated the “Independent Organization” under state law and assigned these responsibilities [Texas Public Utility Regulatory Act (PURA) 39.151]:

- Maintaining System Reliability
- Ensuring Open Access to Transmission
- Facilitating the Competitive Wholesale Market
- Facilitating the Competitive Retail Market


Regulatory Characteristics:

- ERCOT is regulated by the Texas Public Utility Commission with oversight by the Texas Legislature
- ERCOT is not a market participant and does not own generation or transmission/distribution wires
- ERCOT is the sole Reliability Coordinator, Balancing Authority, Planning Authority, Interchange Authority, and Transmission Service Provider for the ERCOT Region


Installed Wind Generation in ERCOT



Wind Output




- **Peak wind generation output on 7,925MW on 4/13/12**
 - 20.1% of Load at the time
- **Maximum Percent of Load Served by Wind was 28.2% on 3/6/12**
- **8.7% of Nameplate Capacity of wind counted towards reserve margin**



Competitive Renewable Energy Zones (CREZ)




- **Transmission Plan designed to serve approximately 18GW:**
 - ~4600 circuit miles of 345 kV
 - \$6.7 billion project cost
- **All line certification cases completed**
 - Construction underway
 - All lines expected to be complete by end of 2013
- **Lines are open-access; use not limited to wind**

Competitive Renewable Energy Zones (CREZ)
Transmission Optimization Study
Figure 5: Scenario 2




Operational Challenges for Wind Integration

- **Uncertainty**
- **Variability**
- **Interconnection**




Wind Forecast

- **Wind power production forecast**
 - Hourly 50% probability of exceedance forecast for a rolling 48 hour period
 - Provided for each wind farm and total for system
- **Used to determine need for “residual” unit commitment**




Wind Forecast Error




Average hour-ahead wind forecast error is significant (MAPE is ~7%)

MW errors may be high (>1000 MW; occasionally >2000 MW)




Predicting Large Ramps in Wind Power Output

- **ERCOT Large Ramp Alert System (ELRAS)**
 - Probabilistic forecast which alerts Operators of ramps during the next 6 hours
 - Provided on the system and regional level



Ancillary Services - Regulation



- ERCOT typically dispatches generation each five minutes
- Regulation Service is used to balance the variation in load and generation between five-minute economic dispatch executions
- Primary driver for determining required amount of regulation is historical deployments
 - Adjusted for increase in installed wind capacity




Ancillary Services – Non-Spin

- **Non-spin Reserve Service**

- 30 minute product that can be provided by unloaded capacity, offline Generators, and Load Resources
- Wind power forecast error is one of the inputs used for calculating the requirement for this service




Ancillary Services – Non-Spin




Primary Frequency Response

- All generation in ERCOT is required to provide governor response with a 5% droop setting
- Wind farms were recently required to provide primary frequency response to frequency deviations from 60 Hz.




Generation Ramps




Interconnection-Related Requirements

- Inverter-connected resources may not fit with traditional technical requirements
- Need to address these issues to maintain system reliability:
- **Static and dynamic reactive capability**
- **Voltage-ride through capability**
- **Modeling**
 - Collector system and support device modeling
 - Dynamic model and parameters



Impact of Wind Generation on Prices

- **There is a clear shift down in the duration curve of real-time prices for higher levels of wind power output**





Questions?